

# 2021 Water Quality Report for City of Ithaca

This report covers the drinking water quality for City of Ithaca for the 2021 calendar year. This information is a snapshot of the quality of the water that we provided to you in 2021. Included are details about where your water comes from, what it contains, and how it compares to United States Environmental Protection Agency (U.S. EPA) and state standards.

Your water comes from 4 groundwater wells, at a depth of, well #4-128', well #5-186', well #6-272', and well #7-141'. The State performed an assessment of our source water to determine the susceptibility or the relative potential of contamination. The susceptibility rating is on a seven-tiered scale from "very-low" to "very-high" based on geologic sensitivity, well construction, water chemistry and contamination sources. The susceptibility of our source is very low.

There are no significant sources of contamination in our water supply. We are making efforts to protect our sources by routine sampling and a Wellhead Protection Program.

If you would like to know more about this report, please contact: Water Superintendent, Jarred Waldron at Ithaca City Hall at 989-875-3200.

**Contaminants and their presence in water:** Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the U.S. EPA's Safe Drinking Water Hotline (800-426-4791).


**Vulnerability of sub-populations:** Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune systems disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. U.S. EPA/Center for Disease Control guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial

contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

**Sources of drinking water:** The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. Our water comes from wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

**Contaminants that may be present in source water include:**

- **Microbial contaminants**, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations and wildlife.
- **Inorganic contaminants**, such as salts and metals, which can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming.
- **Pesticides and herbicides**, which may come from a variety of sources such as agriculture and residential uses.
- **Radioactive contaminants**, which can be naturally occurring or be the result of oil and gas production and mining activities.
- **Organic chemical contaminants**, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems.



In order to ensure that tap water is safe to drink, the U.S. EPA prescribes regulations that limit the levels of certain contaminants in water provided by public water systems. Federal Food and Drug Administration regulations establish limits for contaminants in bottled water which provide the same protection for public health.

## Water Quality Data

The table below lists all the drinking water contaminants that we detected during the 2021 calendar year. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. Unless otherwise noted, the data presented in this table is from testing done January 1 through December 31, 2021. The State allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year. All the data is representative of the water quality, but some are more than one year old.

### Terms and abbreviations used below:

- Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
- Maximum Contaminant Level (MCL): The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
- Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
- Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
- Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water.
- N/A: Not applicable
- ND: not detectable at testing limit
- Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other

### Level 1 Assessment

During the past year we were required to conduct 1 Level 1 Assessment. 1 Level 1 Assessment was completed. In addition, we were required to take 1 corrective action and we completed 1 of these actions requirements that a water system must follow.

### Level 2 Assessment

During the past year we experienced 1 Level 2 assessment. Due to a TC (Total Coliform) event that was system wide. After a 15-day boil water notice in the month of August the problem was resolved. A level 2 assessment was completed, and all corrective actions and requirements were followed. As a result of this we have implemented a new site sampling plan and procedures to prevent this from reoccurring.

### Lead and copper sampling

As per new EGLE standards we are required to sample 10 different sites throughout the city for Lead and copper. With the events of the level 2 assessment, we did not sample these Lead and copper sites as needed. As a result, we will be stepping up the samples for the 2022 year.

Regulated Contaminant	MCL, TT, or MRDL	MC LG or MR DL G	Level Detected	Range	Year Sampled	Violation Yes/No	Typical Source of Contaminant
Arsenic (ppb)	10	0	0.002	ND - 0.002	2019	No	Erosion of natural deposits; Runoff from orchards; Runoff from glass and electronics production wastes
Barium (ppm)	2	2	0.10	0.07 – 0.10	2019	No	Discharge of drilling wastes; Discharge of metal refineries; Erosion of natural deposits
Nitrate (ppm)	10	10	Non Detected	N/A	2021	No	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
Fluoride (ppm)	4	4	0.71	0.55 – 0.71	2020	No	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories
Sodium <sup>1</sup> (ppm)	N/A	N/A	58	22 - 58	2020	No	Erosion of natural deposits
TTHM Total Trihalomethanes (ppb)	80	N/A	N/A	N/A	N/A		Byproduct of drinking water disinfection
HAA5 Haloacetic Acids (ppb)	60	N/A	N/A	N/A	N/A		Byproduct of drinking water disinfection
Chlorine <sup>2</sup> (ppm)	4	4	N/A	N/A	N/A		Water additive used to control microbes
Alpha emitters (pCi/L)	15	0	1.6 +/- 1.4		2020	No	Erosion of natural deposits
Combined radium (pCi/L)	5	0	1.14 +/- 0.69		2018	No	Erosion of natural deposits
Total Coliform (total number or % of positive samples/month)	TT	N/A	2	N/A	2021	Yes	Naturally present in the environment
E. coli in the distribution system (positive samples)	See E. coli note <sup>3</sup>	0	0	N/A	2021	No	Human and animal fecal waste
Fecal Indicator – E. coli at the source (positive samples)	TT	N/A	0	N/A	2021	No	Human and animal fecal waste
Inorganic Contaminant Subject to Action Levels (AL)	Action Level	MC LG	Your Water <sup>4</sup>	Range of Results	Year Sampled	Number of Samples Above AL	Typical Source of Contaminant
Lead (ppb)	15	0	2ppb	0-97	2018	1	Lead service lines, corrosion of household plumbing including fittings and fixtures; Erosion of natural deposits
Copper (ppm)	1.3	1.3	0.11 ppm	0.05 – 0.26	2018	0	Corrosion of household plumbing systems; Erosion of natural deposits

**Information about lead:** If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. [NAME OF UTILITY] is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

Infants and children who drink water containing lead in excess of the action level could experience delays in their physical or mental development. Children could show slight deficits in attention span and learning abilities. Adults who drink this water over many years could develop kidney problems or high blood pressure.

Copper is an essential nutrient, but some people who drink water containing copper in excess of the action level over a relatively short amount of time could experience gastrointestinal distress. Some people who drink water containing copper in excess of the action level over many years could suffer liver or kidney damage. People with Wilson's Disease should consult their personal doctor.

Monitoring and Reporting to the Department of Environment, Great Lakes, and Energy (EGLE) Requirements: The State of Michigan and the U.S. EPA require us to test our water on a regular basis to ensure its safety. We met all the monitoring and reporting requirements for 2021.

We will update this report annually and will keep you informed of any problems that may occur throughout the year, as they happen. Copies are available at Ithaca City Hall Monday – Friday, from 8:00am to 4:00pm.

We invite public participation in decisions that affect drinking water quality. Council Meetings are held the 1<sup>st</sup> and 3<sup>rd</sup> Tuesday of every month at 7:00pm. For more information about your water, or the contents of this report, contact Water Superintendent Jarred Waldron at 989-875-3200 or visit our website at [www.ithacami.com](http://www.ithacami.com).

For more information about safe drinking water, visit the U.S. EPA at <http://www.epa.gov/safewater>.